

Zeta vrijednosti sustava press spojnica

Za instalacije pitke vode

Određeno sukladno principima ispitivanja DVGW W 575 za

Viega Smartpress

Sadržaj – Tablice

Viega Smartpress 2

Bauteil	Sanpress		Zeta-Wert		
	DVGW W 575	Graphisch veranschaulicht	DN 12 Da / 15 mm	DN 15 Da / 18 mm	DN 20 Da / 22 mm
 T-Stück Abzweig			1,9	1,9	0,9
 T-Stück Durchgangs			0,6	0,6	-0,3
 Winkel / Bogen 90°			0,7	1,1	1,0
 Winkel / Bogen 45°			1,4	1,4	1,6
 Wandscheibe			1,5	1,5	3,6
 Kupplung / Muffe			0,4	0,4	0,4

Viega Smartpress			Zeta vrijednosti									
DVGW W575			DN12	DN15	DN20	DN25	DN32	DN40	DN50			
Komponenta	Pojedinačni otpor	Kratka oznaka	Grafički simbol	d _a 16mm	d _a 20mm	d _a 25mm	d _a 32mm	d _a 40mm	d _a 50mm	d _a 63mm		
	T-komad odvojak	TA		3,6	3,7	4,7	4,1	2,7	3,2	4,5		
	T-komad prolazni	TD		2,0	1,7	2,1	1,4	0,8	0,8	0,9		
	T-komad protustrujno razdvajanje toka	TG		4,3	3,4	4,9	3,9	2,6	3,2	4,6		
	T-komad odvojak sjedinjavanje tokova	TVA		7,9	6,2	8,6	6,5	4,2	5,5	8,0		
	T-komad prolazni sjedinjavanje tokova	TVD		15,0	11,5	16,2	12,7	8,1	10,9	16,7		
	T-komad protustrujno sjedinjavanje tokova	TVG		10,5	7,2	9,9	7,5	4,8	5,2	8,2		
	Koljeno 90°	W90		2,7	2,1	2,6	1,9	1,2	1,1	1,5		
	Koljeno 45°	W45		-	-	2,2	1,5	0,9	0,9	1,1		
	Reduktor	RED		-	1,9	2,3	2,7	1,4	0,8	1,0		
	Zidna pločica	WS		2,5	2,4	-	-	-	-	-		
	Dvostruka zidna pločica prolazni	WSD		3,9	3,8	4,5	-	-	-	-		
	Dvostruka zidna pločica odvojak	WSA		3,6	3,6	5,8	-	-	-	-		
	Spojnica / kolčak	K		2,1	1,5	1,8	1,2	0,7	0,7	0,7		